

Packaged Terminal Air Conditioner for Replacement

RSCM/A/B/C Series

Ice Air's RSCM/A/B/C Series Replacement and Retrofit units are high energy efficiency PTACs. Designed from the ground up for ultra-high efficiency, they incorporate advanced LEEDs features in a durable and user-friendly package.

Features:

- Ultra-high efficiency – EERs to 10.5
- Advanced tangential indoor blower provides balanced air flow
- Whisper quiet sound levels
- Standard programmable digital touchpad controls
- 5/2 or 7 day programming
- Heavy duty, commercial-grade construction throughout
- G90 galvanized steel construction, powder-coated drain and base pans
- Furniture-grade, powder-coated cabinetry



RSCM/A Replaces:

ClimateMaster 702, 703, 704
 Friedrich – 702, 703, 704
 Weil-McClain – 702, 703, 704
 Islandaire – CM
 Retroaire – RC/RH20

RSCM/B and RSCM/C Replaces:

ClimateMaster – 700 AD
 Friedrich – 700 AD
 Weil-McClain – 700 AD
 Islandaire – AD
 Retroaire – RC/RH20

SERIES MODEL #	5RSCM09	5RSCM13	8RSCM09	8RSCM13	8RSCM18	7RSCM09	7RSCM13	7RSCM18
Cooling Capacity (Btu/h)¹	9,500	12,750	9,700	13,250	17,300	9,250	12,500	17,000
EER	10.5	8.2	10.3	8.1	7.7	10.5	10	9.3
Heating Capacity - Hot Water (Btu/h)²	8,650	11,600	8,830	12,060	15,740	8,420	11,380	15,470
Heating Capacity - Steam (Btu/h)³	2.7	2.6	2.7	2.6	2.5	2.7	2.6	2.5
Electric Heating MAX (kW)	1.5	1.5	4.3	4.3	4.3	3.5	3.5	3.5
Voltage	115	115	208/230	208/230	208/230	277	277	277
Amperage	7.9	13.5	4.5	7.9	10.8	3.2	4.5	6.6
Watts	905	1,555	942	1,636	2,247	881	1,250	1,828
CFM Room Air High	370	370	370	430	480	370	430	480
Weight Net/Ship	113/129	117/133	113/129	124/138	141/157	117/133	124/139	141/157

SPECIFICATION NOTES:

1. BTUH @ 80°F. DB/67 °F. WB INDOORS; 95 °F. DB OUTDOORS.
2. BTUH @ 47°F. DB/43 °F. WB OUTDOORS; 70°F DB/60°F DB INDOORS.
3. HEAT PUMP OPERATION DISABLED BELOW 38 °F (+/- 3 °F)

IMPORTANT: Accessories are optional. Deviations from standard accessories may affect performance; louver requires 70% free area per original OEM specification; room enclosures must provide sufficient return air, free flowing supply air and must be properly sealed to prevent air recirculation; any non-standard components or accessories must be reviewed and approved by Ice Air or approved distributor.